

General Services - O&A#201418A

Liquid Fuel Funding Road Review - O&A#201318A (no change)

Hose House alley and Day Way need improved to be added

Street Opening Ordinance (no change)

PADOT Paving Project - State Route 56/66

3 Inlets were noted for repair/replacement - PADOT could include work in bid if Apollo Pays

Inlets at end of Wilson Way & across from N. 7th st

Public works can fix before paving

Handicap Ramp will be done by PADOT as part of work

4 at N. 9th, 2 at Wilson, 3 at N. 3rd,

Ramps/crossings were not indicated at N. 8th and N. 2nd Street

Does Council want to press PADOT for ramps at these intersections?

PADOT is planning on bidding this project in the next week

Steele Lot Line Revision - O&A#201218B.02 (no change)

Need agreement finalized and document to be signed & recorded

Apollo Borough Sanitary Sewer Services - O&A#201418C

KVWPCA flow reduction report - no new information this month (no change)

River Outfalls (No change)

Locations of diversions made to River to date (N. 11th, Parcel A, Standford or N. 4th, N. 3rd)

KVWPCA will add ownership transfer of diversion manholes to acknowledgement

Borough & KVWPCA may want to switch KVWPCA manhole lids (Sanitary to Storm)

KVWPCA & Borough to review Parcel A invert issue

Outflow higher than inflow

May create a future maintenance issue

May want to place concrete in invert prior to property transfer

KVWPCA Manhole at end of S. 2nd and River - Erosion around manhole

Reviewed in field 1/24/14 and took pictures

Manhole lid off - was off when reviewed previously

KVWPCA must have a surcharging problem in the line - emailed KVWPCA

Could eventually expose pipe creating a greater potential for pipe damage & line freezing

Riprap stone should be placed to repair and prevent future erosion

KVWPCA should cap abandoned line to reduce infiltration

2014 PADEP required reporting data to KVWPCA by Apollo

O&A to prepare calculations and respond to KVWPCA request for data

KVWPCA Project Update - Brian Johnston

New plant work nearly complete

New flow monitoring

KVWPCA has not yet set a start date for new flow monitoring

The Borough will want to coordinate flow monitoring locations with KVWPCA

KVWPCA may delay flow monitoring to wait for the completion of other separation projects

Vandergrift, East Vandergrift, Kiski Township, Apollo,

PENNVEST Loan

Must have final loan payment on 4/1/2031 - two options for payback

Pay principle to date (\$70,924.09 as of 4/1/14) and continue payments at \$2,065.85

Revise term from 20 years to 17 years with payment of \$2,384.63 - due 4/1/2014

Apollo Revenues from last year

Residential (789 @ \$28), Commercial (72 @ \$28), Empty lot (72 @ \$14)

\$100,464 per year, \$25,116 per quarter, or \$8,372 per month

Apollo Costs

\$5,552.14 per month to First Commonwealth for \$1,000,000 loan

\$433.33 per month - Salaries, Postage, Insurance, etc.

One of the above loan options

The net difference above is \$2,386.53

Option 1 would deplete current funds but provide extra \$320.68 a month in revenue

Option 2 would leave current funds in places with only \$1.90 a month in extra revenue

New LGUDA proceedings would be needed to change loan info. With State

Conference-call with PENNVEST scheduled for 2/5/14 (need decision by then)

May still have an issue where Borough is being asked to pay interest on money not yet rec.

Storm Damage Review - O&A#201318D

Is Apollo Council going to be setting up a committee to review this issue?